

**GOVERNMENT OF ANDHRA PRADESH**  
**STATE DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT**

From:  
The Director General,  
State Disaster Response & Fire Services  
Andhra Pradesh, Vijayawada.

To:  
The Management,  
I-DPS under Malineni Perumallu  
Educational Society, Sy.No.355/2,  
Kanumalla Village, Singarayakonda  
Mandal, Prakasam District.

**E.Office No.13194287/MSB/PRK/2026, Dated: /1-09-2026.**

Sir,

Sub:- A.P State Disaster Response & Fire Services Department- MSB- Issuance of Name Change to the Existing Building from Malineni Perumallu Educational Society (School Building) to I-DPS under Malineni Perumallu Educational Society, Sy.No.355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District - Regarding.

- Ref:-
1. Occupancy NOC issued File.No. .20585/PRK/RFO/2023, dt.12-12-2023 of the Regional Fire Officer, Zone-III, Guntur.
  2. Name Change proposal of M/s Malineni Perumallu Educational Society, Mulaguntapadu, Singarayakonda, Prakasam District.

-<< 0 >>-

The Management has obtained Occupancy No Objection Certificate from this Department vide reference 1<sup>st</sup> cited to the Existing Building on the name of Malineni Perumallu Educational Society (School Building), Sy.No.355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District.

2) Vide reference 2<sup>nd</sup> cited the Management of M/s Malineni Perumallu Educational Society, Mulaguntapadu, Singarayakonda, Prakasam District has requested that they have Changed their building name from Malineni Perumallu Educational Society (School Building) to I-DPS under Malineni Perumallu Educational Society and requested to Change the name of their Building in Fire No Objection Certificate. The Management has remitted the Fire Precautionary Fee of Rs.2000/- vide Challan No.11198727792026 Dated:09-09-2026 towards the Change of their building Name into Government account through online payment as per G.O.Ms.No.71, Home (Prisons-A) Department, Dated:01-04-2010.

3) Under the above circumstances and taking into consideration of request of the management, the Change of name from Malineni Perumallu Educational Society (School Building) to I-DPS under Malineni Perumallu Educational Society, Sy.No.355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District of the said premises is here by modified.

Yours sincerely,

Digitally signed by  
VENKATA RAMANA PENIKALAPATI  
Date: 11-09-2026 13:54:12

Director of Fire Services (Technical)  
(HFAC) Director General  
State Disaster Response and Fire Services  
Andhra Pradesh, Vijayawada.



**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**No Objection Certificate for Occupancy**

To  
 The District Educational Officer,  
 Educational Department, Prakasam District,  
 Ongole  
 Sir/Madam,

File No: 20585/PRK/RFO/2023.

Date: 12/12/2023.

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - No Objection Certificate for Occupancy to the existing / newly constructed Multi Storeyed Building (Malineni Perumallu Educational Society (School Building)) Malineni Perumallu, Survey No. 355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District - Regarding.

Ref: 1. Online Application Dt. 17-11-2023, Malineni Perumallu, Survey No. 355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District

2. Online Inspection Report submitted by Officers of this Department on 12-12-2023.

- x -

It is to inform that Malineni Perumallu applied for No Objection Certificate on 17-11-2023 for Occupancy to the existing / newly constructed Multi Storeyed Building for Malineni Perumallu Educational Society (School Building) at Survey No. 355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District. The officers of the department have scrutinized the information, documents and plans submitted by the applicant along with the undertaking provided by the applicant, and have submitted the following report.

**Malineni Perumallu Educational Society (School Building)**

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + 2 Upper Floors with a height of 14.35 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 24281.14 sq. meters.
3. The builder has provided open spaces all around the building

| Side  | Open Space Required as per 119 APBR 2016 | Open Space Provided by the Builder |
|-------|------------------------------------------|------------------------------------|
| North | 6 Meters                                 | 6.00 Meters                        |
| East  | 3 Meters                                 | 6.00 Meters                        |
| South | 6 Meters                                 | 6.00 Meters                        |
| West  | 6 Meters                                 | 6.00 Meters                        |

4. The builder has constructed following means of escape:

| Sl | Details of Staircases | Required Nos / Meters as per A.P.B.R. | Required based on Floor Area | Provided Nos / Meters |
|----|-----------------------|---------------------------------------|------------------------------|-----------------------|
| 1  | Internal Staircases   | Min 1 No. - Meters                    | --                           | 1 No. - 2.50 Meters   |
| 2  | External Staircases   | Min 1 No. - Meters                    | --                           | 1 No. - 1.00 Meters   |
|    | Total                 | 2 Nos.                                | 2.00 Meters                  | 3.5 Meters            |

5. The builder has proposed to provide Occupant Load :

| Sl | Floor  | Built up area (Sq Mtrs) | Occupancy Type | No of Occupants as declared by the builder | No of Occupants as per NBC | Aggregate width of Staircases Required (Meters) | Aggregate width of Staircases Provided (Meters) |
|----|--------|-------------------------|----------------|--------------------------------------------|----------------------------|-------------------------------------------------|-------------------------------------------------|
| 1  | Ground | 957.35                  | Educational    | 239                                        | 239                        | 2.39                                            | 3.50                                            |
| 2  | First  | 1031.94                 | Educational    | 257                                        | 257                        | 2.57                                            | 3.50                                            |

| Sl | Floor  | Built up area<br>(Sq Mtrs) | Occupancy<br>Type | No of<br>Occupants as<br>declared by<br>the builder | No of<br>Occupants as<br>per NBC | Aggregate<br>width of<br>Staircases<br>Required<br>(Meters) | Aggregate width of<br>Staircases<br>Provided (Meters) |
|----|--------|----------------------------|-------------------|-----------------------------------------------------|----------------------------------|-------------------------------------------------------------|-------------------------------------------------------|
| 3  | Second | 1031.94                    | Educational       | 257                                                 | 257                              | 2.57                                                        | 3.50                                                  |
|    | Total  | 3021.23                    |                   | 753                                                 | 753                              |                                                             |                                                       |

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

| Sl | Fire Safety System              | Minimum Required | Provided   |
|----|---------------------------------|------------------|------------|
| 1  | Fire Extinguishers              | 32 Nos.          | 32 Nos.    |
| 2  | Hose Reel Systems               | 5 Nos.           | 5 Nos.     |
| 3  | Terrace Tank                    | 10000 Ltrs       | 10000 Ltrs |
| 4  | Booster Pump                    | 450 LPM          | 450 LPM    |
| 5  | Additional Fire Safety measures | NA               |            |

7. The builder has provided the following floorwise Fire Fighting installations as per Table 7 of Part-4 of NBC of India 2016.

| Sl | Floor  | Fire Hose<br>Ext. Reel | Wet<br>Riser | Down<br>Comer | Yard<br>Hydrants | Sprinklers | MCP | Auto.<br>Det. | Underground<br>Tank | Terrace<br>Tank                         | Fire<br>Pump | Booster<br>Pump                  | Addl      |
|----|--------|------------------------|--------------|---------------|------------------|------------|-----|---------------|---------------------|-----------------------------------------|--------------|----------------------------------|-----------|
| 1  | Ground | 10<br>/10              | 1/1          |               |                  | 0/-        | 0/- | 0/-           |                     |                                         |              |                                  |           |
| 2  | First  | 11<br>/11              | 2/2          |               |                  | 0/-        | 0/- | 0/-           |                     |                                         |              |                                  |           |
| 3  | Second | 11<br>/11              | 2/2          |               |                  | 0/-        | 0/- | 0/-           |                     |                                         |              |                                  |           |
|    | Total  | 32<br>/32              | 5/5          | --/--         | --/--            | 0/0        | 0/0 | 0/0           | --/--               | 10000<br>Ltrs<br>/10000<br>Ltrs<br>Ltrs | --/--        | 450<br>LPM<br>/450<br>LPM<br>LPM | NA<br>/-- |

\* Provide ABC 5 kg/6 kg fire extinguishers

8. The Officers of the department have recommended to issue The No Objection Certificate for Occupancy of Non MSB Educational Building (B1) belonging to Mallineni Perumallu Survey No. 355/2, Kanumalla Village, Singarayakonda Mandal, Prakasam District, subject to the following conditions:

The No Objection Certificate for Occupancy is issued subject to the following conditions:

1. This NOC is issued only in the Fire Safety Point of View and this does not give the Applicant a right to claim ownership of the property.
2. All fire safety systems provided shall be maintained in trim working condition at all times.
3. All Security/ Maintenance personnel shall be trained on the usage of fire equipment provided.
4. Fire Drills shall be conducted once in every 3 months.
5. As per report of Non MSB Inspection committee; the NOC Committee has scrutinized the Inspection Committee Report along with Proposals and recommended for issuance of No Objection Certificate for Occupancy subject to the following Conditions.

| Sl | As Builder                                                                                            | As Occupant                                                                | As Security Personnel                                                                              |
|----|-------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------|
| 1  | All the fire protection arrangements shall be maintained in good condition as seen during inspection. | All the escape/exit routes shall not be kept locked/blocked or encroached. | All the occupants must know the correct method of operation of the fire fighting system installed. |


|   |                                                                                                                                                    |                                                                                                                |                                                                                                                                                                  |
|---|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2 | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management. | All occupants shall be trained to operate the fire safety equipments during emergency.                         | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.                                                      |
| 3 | Addition / alteration, if any in the building may be verified by building authority.                                                               | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.    | All security personnel shall be trained to operate the fire safety equipments during emergency.                                                                  |
| 4 | This No objection Certificate for occupancy is valid for one year from the date of issue of this letter                                            | Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once from nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |

6. This No Objection Certificate for Occupancy is valid for a period of Three years only from the date of issue of this letter. It is the responsibility of the builder to apply for Renewal of No-Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.71, Home (Prison-A) Department, dated 01-04-2010 and G.O.Ms.No.140, Home (Prison & Fire) Department, dated.04-09-2015, before expiry of this No Objection Certificate.


9. The following deficiencies are identified by the officers of the department and need to be attended to by the management.

The inspection committee reported the good working condition of Fire safety measures.

In view of the above, as per the recommendations of the NOC Committee, the No-Objection Certificate for Occupancy is hereby issued to the Newly constructed Non Multi Storeyed Building subject to the above conditions.

Your Sincerely,  
  
 Regional Fire Officer,  
 Zone-III, Guntur,

Copy to Malineni Perumallu, Malineni Perumallu Educational Society (School Building), Survey No. 355/2, Kanumalla Village, Singarayakonda Mandal, Prakasani District.  
 Copy to Chief Office for Record Purpose  
 Copy to District Fire Officer concerned  
 Copy to Assistant District Fire Officer concerned  
 Copy to Station Fire Officer concerned

  
 7.12/12